



Technical Bulletin

SEER2 MULTI-ZONE INDOOR UNIT COMPATIBILITY

Document #: PB-DLS-08262022

Date Issued: August 25, 2022

Author: Chuck Jacobs

Reference: Compatibility of CAS, DUCT, FLR as well as all High-Wall units when matched with multi-zone outdoor units.

Product Group: Indoor Units

Models Affected: All Multi-Zone Units

Serial Number Range: ALL

Summary:

This bulletin is being released in response to customer inquiries regarding backwards compatibility of new SEER2 indoor units with existing Multi-Zones as well as forward compatibility of existing indoor units with new SEER2 Multi-Zone outdoor units.

- **All current and future IDU's will be compatible with the new SEER2 Multi's.**
- **Any SEER2 IDU will be compatible with the current A, B, C model Multi's and B & D model MULTIU's.**